

تاريخ الطباعة : 2023-05-16  
وقت الطباعة : AM 8:39  
رقم الطلب : PAC23004890



وزارة الداخلية  
الإدارة العامة للدفاع المدني  
إدارة الوقاية

### شهادة عدم ممانعة

نوع الشهادة : اعتماد منتج

### بيانات المنشأة

الإسم التجاري : الباتجارة والمقاولات

رقم السجل التجاري : 129595

رقم الرخصة التجارية : 81710

رقم قيد المنشأة : 10-5321-32

رقم الهاتف :

البريد الإلكتروني :

التصنيف : Passive Fire Protection System

إسم المنتج : Fire Rated Door Assemblies

### تفاصيل الشهادة

تم مراجعة الطلب المقدم واتضح بأنه لا مانع من اعتماد المنتج/المنتجات الموضحة في التقرير الفني المرفق بناءً على اعتماده من قبل الهيئته المختبرية الموضحة في التقرير الفني المرفق.

### ملاحظات

1. يجب على الشركة الالتزام والعمل بما جاء في اشتراطات قسم أنظمة السلامة التي تم الاطلاع والموافقة عليها من خلال الموقع.
2. يجب ان يقوم بتركيب هذا المنتج من قبل مهندسين وفنيين معتمدين من الإدارة العامة للدفاع المدني.
3. يجب ان يحمل المنتج العلامة التجارية للهيئته المختبرية المعتمدة والموضحة في التقرير الفني المرفق.

تاريخ الاعتماد : 2023-05-14 تاريخ الإنتهاء : 2025-05-13

عدير إدارة الوقاية  
الإدارة العامة للدفاع المدني



DATE : 2023-05-16 : التاريخ  
PERMIT # PAC23004890 : رقم الطلب



وزارة الداخلية  
الإدارة العامة للدفاع المدني  
إدارة الوقاية

## TECHNICAL REPORT

التقرير الفني

PRODUCT	Fire Rated Door Assemblies	منتج
PRODUCT APPLICATION	Passive Fire Protection System	تصنيف المعدة
APPLICANT / P.O BOX	البا لتجارة والمقاولات	مقدم الطلب
MANUFACTURER / LOCATION	SHAKTI HORMANN PVT LTD / INDIA	الشركة المصنعة / بلد الصنع

الوصف

الموديل

Fire Resistant Roller Shutter. Roller shutter doors. The shutter, which may be fabricated using wither mild steel or stainless steel components, which are fitted with an industrial type motor (excluding tubular motor), designed to suit openings in masonry/concrete constructions and fire protected steel structures up to for fire resistance periods up to 4 hours.	Fire Resistant Roller Shutter / CF 5545
---	---

3RD PARTY CERTIFICATE / APPROVAL	CF5545	WARRINGTONFIRE	شهادة المختبرات المساندة (من هيئات معتمدة)
----------------------------------	--------	----------------	---

RECOMMENDATIONS		التوصيات
-----------------	--	----------

### NOTES / STANDARDS

Refer to Certifire Certificate no. CF 5545 for the full details.

Tested to standard BS 476: Part 22

This product approval shall comply with the NFPA 80 (and/or other related NFPA Codes / Standards), other acceptable International Codes / Standards, Local Regulations, Listing Instructions and/or Manufacturer's Published Instructions subject to the technical review and approval of the Authority Having Jurisdiction / Qatar Civil Defence.

عبدالله بن محمد  
مدير إدارة الوقاية  
الإدارة العامة للدفاع المدني

